



July 10, 2020

Chris Cross
Cedar Shores Campground
5916 Cedar Shores Drive
Harrison, MI 48625

Project:
Cedar Shores
Harrison, MI

To Whom It May Concern,

Upon thorough investigation it has been found that the primary cabling throughout the park, when at full capacity, is inadequate due to increased draw demands being placed on the system.

It is critical to do some repairs to the electrical grid at the Cedar Shores Campground facility and rebalance the loads on the distribution panels throughout the park. Currently the unbalanced load can cause nuisance tripping resulting in some sites losing power. This could create an emergency situation for any resident that may be on oxygen or require the use of a CPAP machine or any other life saving device that is electrically powered.

Please contact me at (989) 567-1703 if you have any questions or would like further explanation.

Thank You,

Dave Kall
Estimator/Senior Project Manager